



EXTRA NOTES

1. COVER OF REINFORCEMENT TO BE 40 mm FOR THE INNER FACE AND 30 FROM OUTER FACE.
2. 300mm MIN OVERLAP FOR ALL REINFORCEMENT.
3. ALL CONCRETE TO BE 30 MPa/19mm.
4. DESLUDGING AT 6 MONTHS INTERVAL REQUIRED.
5. EMPTYING AT 3 MONTHS INTERVAL REQUIRED.

